

Compliance Designs

CLIENT: Harvest Springs
743 Broad Street, Unit #1
East Weymouth, MA 02189

DATE OF REPORT: Quarter 1, 2020
REPORT #: 664-033
LABORATORY ID#: 851894

NOTE: ****** indicates that maximum levels have been exceeded, or in the case of pH, is either too high or too low
"ND" indicates that none of this analyte has been detected at or above the specified detection level
"MCL" indicates maximum contaminant level as established by NYSHD for bottled water
"RL" indicates laboratory reporting limit for method
Units results are reported in mg/L unless otherwise noted

ANALYSIS PERFORMED	MCL ¹ (mg/L)	RL (mg/L)	HARVEST SPRING SOURCE-TREATED 664-033 (mg/L)
Primary Inorganics			
Antimony	--	0.001	ND
Arsenic	0.05	0.002	ND
Barium	1	0.002	0.0068
Cadmium	0.01	0.0005	ND
Chromium	0.05	0.005	ND
Fluoride	2.2	0.05	ND
Lead	0.05	0.0005	ND
Mercury	0.002	0.0002	ND
Nickel	--	0.005	ND
Nitrogen, Nitrate	10	0.1	0.71
Nitrogen, Nitrite	--	0.05	ND
Nitrogen - NO3/NO2 (NOX)	10	0.1	0.71
Selenium	0.01	0.005	ND
Secondary Inorganics			
Alkalinity	--	2	17
Bicarb. Alkalinity	--	2	21
Calcium	--	1	6.6
Chloride	250	0.5	12
Copper	1	0.002	ND
Corrosivity	--	-14	-2.6
Hardness, Total	--	3	27
Iron	0.3	0.02	ND
Magnesium	--	0.1	2.5
Manganese	0.3	0.002	0.0037
pH	--	0.1	6.7
Silver	0.05	0.0005	ND
Sodium	--	1	7.9
Sulfate	250	0.5	7.7
TDS	--	10	64
Zinc	5	0.02	ND
Physical			
Color	--	3	ND
Odor	--	1	1.0
Turbidity	--	0.1	0.13
Radiologicals			
Gross Alpha	15 pCi/L	3	ND
Gross Beta	50 pCi/L ²	3	ND
Radium 226/228	5 pCi/L	1 / 1	ND / ND

ANALYSIS PERFORMED	MCL (mg/L)	RL (mg/L)	HARVEST SPRING SOURCE-TREATED 664-033 (mg/L)
Volatile Organic Compounds			
EPA 524.2:			
Total Trihalomethanes	0.1	0.0005	ND
tert-Amyl Methyl Ether (TAME)	--	0.003	ND
tert-Butyl-Ethyl Ether (TBEE)	--	0.003	ND
Benzene	0.005	0.0005	ND
Bromobenzene	0.005	0.0005	ND
Bromochloromethane	0.005	0.0005	ND
Bromodichloromethane	--	0.0005	ND
Bromoform	--	0.0005	ND
Bromomethane	0.005	0.0005	ND
n-Butylbenzene	0.005	0.0005	ND
sec-Butylbenzene	0.005	0.0005	ND
tert-Butylbenzene	0.005	0.0005	ND
Carbon Disulfide	--	0.0005	ND
Carbon Tetrachloride	0.005	0.0005	ND
Chlorobenzene	0.005	0.0005	ND
Chloroethane	0.005	0.0005	ND
Chloroform	--	0.0005	ND
Chloromethane	0.005	0.0005	ND
2-Chlorotoluene	0.005	0.0005	ND
4-Chlorotoluene	0.005	0.0005	ND
Chlorodibromomethane	--	0.0005	ND
Dibromomethane	0.005	0.0005	ND
1,2-Dichlorobenzene	0.005	0.0005	ND
1,3-Dichlorobenzene	--	0.0005	ND
1,4-Dichlorobenzene	0.005	0.0005	ND
Dichlorodifluoromethane	0.005	0.0005	ND
1,1-Dichloroethane	0.005	0.0005	ND
1,2-Dichloroethane	0.005	0.0005	ND
1,1-Dichloroethylene	0.005	0.0005	ND
cis-1,2-Dichloroethylene	0.005	0.0005	ND
trans-1,2-Dichloroethylene	0.005	0.0005	ND
1,2-Dichloropropane	0.005	0.0005	ND
1,3-Dichloropropane	0.005	0.0005	ND
2,2-Dichloropropane	0.005	0.0005	ND
1,1-Dichloropropene	0.005	0.0005	ND
cis-1,3-Dichloropropene	0.005	0.0005	ND
trans-1,3-Dichloropropene	0.005	0.0005	ND
Di-Isopropyl Ether	--	0.003	ND
Ethylbenzene	0.005	0.0005	ND
Hexachlorobutadiene	0.005	0.0005	ND
Isopropylbenzene	0.005	0.0005	ND
4-Isopropyltoluene	0.005	0.0005	ND
4-Methyl-2-Pentanone (MIBK)	--	0.005	ND
Methyl tert-Butyl Ether (MTBE)	--	0.0005	ND
Methyl Ethyl Ketone (MEK)	--	0.005	ND
Methylene Chloride	0.005	0.0005	ND
Naphthalene	--	0.0005	ND
n-Propylbenzene	0.005	0.0005	ND
Styrene	0.005	0.0005	ND
1,1,1,2-Tetrachloroethane	0.005	0.0005	ND
1,1,2,2-Tetrachloroethane	0.005	0.0005	ND
Tetrachloroethylene	0.005	0.0005	ND
Toluene	0.005	0.0005	ND
1,2,3-Trichlorobenzene	0.005	0.0005	ND
1,2,4-Trichlorobenzene	0.005	0.0005	ND
1,1,1-Trichloroethane	0.005	0.0005	ND

ANALYSIS PERFORMED	MCL (mg/L)	RL (mg/L)	HARVEST SPRING SOURCE-TREATED 664-033 (mg/L)
EPA 524.2 continued:			
1,1,2-Trichloroethane	0.005	0.0005	ND
Trichloroethylene	0.005	0.0005	ND
Trichlorofluoromethane	0.005	0.0005	ND
Trichlorotrifluoroethane	--	0.0005	ND
1,2,3-Trichloropropane	0.005	0.0005	ND
1,2,4-Trimethylbenzene	0.005	0.0005	ND
1,3,5-Trimethylbenzene	0.005	0.0005	ND
Vinyl Chloride	0.002	0.0003	ND
m+p-Xylenes	0.005	0.0005	ND
ortho-Xylene	0.005	0.0005	ND
Total Xylene	0.005	0.0005	ND
Add'l Organics			
EPA 505:			
Alachlor	--	0.0001	ND
Aldrin	--	0.00001	ND
Chlordane (alpha and gamma)	--	0.0001	ND
Dieldrin	--	0.00001	ND
Endrin	0.0002	0.00001	ND
Heptachlor	--	0.00001	ND
Heptachlor Epoxide	--	0.00001	ND
Lindane	0.004	0.00001	ND
Methoxychlor	0.05	0.00005	ND
Total PCBs	--	0.0001	ND
PCB 1016	--	0.00008	ND
PCB 1221	--	0.0001	ND
PCB 1232	--	0.0001	ND
PCB 1242	--	0.0001	ND
PCB 1248	--	0.0001	ND
PCB 1254	--	0.0001	ND
PCB 1260	--	0.0001	ND
Toxaphene	0.005	0.0005	ND
EPA 515.4:			
Acifluorfen	--	0.0002	ND
Bentazon	--	0.0005	ND
2,4-D	0.05	0.0001	ND
2,4-DB	--	0.002	ND
Dalapon	--	0.001	ND
DCPA (total Mono & Di acid degradate)	--	0.0001	ND
Dicamba	--	0.0001	ND
3,5-Dichlorobenzoic Acid	--	0.0005	ND
Dichlorprop	--	0.0005	ND
Dinoseb	--	0.0002	ND
Pentachlorophenol	--	0.00004	ND
Picloram	--	0.0001	ND
2,4,5-T	--	0.0002	ND
2,4,5-TP (Silvex)	0.01	0.0002	ND
Disinfection Byproducts			
EPA 317:			
Bromate	0.010	0.005	ND

EPA approved methods were used in all of the analyses and a listing is available upon request. These test results may be used for compliance purposes as required.

¹ The FDA, EPA, some State agencies and/or the IBWA may have established alternate MCLs for some of these analytes. Please refer to Federal, State and Industry codes.

² The bottled water shall not contain beta particle and photon radioactivity from man-made radionuclides in excess of that which would produce an annual dose equivalent to the total body or any internal organ of 4 millirems per year calculated on the basis of an intake of 2 liters of the water per day (=50 pCi/L).

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)



AT-1807

Laboratory Report

for

Rocky Harvest, LLC
181 Rear Brook Street
Plympton, MA 02367
Attention: (664) Water Quality Manager -
Plympton, MA

Date of Issue
03/11/2020


EUROFINS EATON
ANALYTICAL, LLC



UTAH ELCP CA00006

Report:851894
Project:664-RKY
Group:NY Annual

LXG: Linda Geddes
Project Manager

* Accredited in accordance with TNI 2016 and ISO/IEC 17025:2017.

* Laboratory certifies that the test results meet all **TNI 2016 and ISO/IEC 17025:2017** requirements unless noted under the individual analysis.

* Following the cover page are State Certification List, ISO/IEC 17025:2017 Accredited Method List, Acknowledgement of Samples Received, Comments, Hits Report, Data Report, QC Summary, QC Report and Regulatory Forms, as applicable.

* Test results relate only to the sample(s) tested.

* Test results apply to the sample(s) as received, unless EEA-M collected and analyzed the sample(s) as noted in the COC and final report.

* This report shall not be reproduced except in full, without the written approval of the laboratory.

* This report includes ISO/IEC 17025:2017 and non-ISO/IEC 17025:2017 accredited methods.

STATE CERTIFICATION LIST

State	Certification Number	State	Certification Number
Alabama	41060	Montana	Cert 0035
Arizona	AZ0778	Nebraska	Certified
Arkansas	Certified	Nevada	CA000062018
California	2813	New Hampshire *	2959
Colorado	Certified	New Jersey *	CA 008
Connecticut	PH-0107	New Mexico	Certified
Delaware	CA 006	New York *	11320
Florida *	E871024	North Carolina	06701
Georgia	947	North Dakota	R-009
Guam	18-005R	Oregon *	CA200003-005
Hawaii	Certified	Pennsylvania *	68-565
Idaho	Certified	Puerto Rico	Certified
Illinois *	200033	Rhode Island	LAO00326
Indiana	C-CA-01	South Carolina	87016
Iowa - Asbestos	413	South Dakota	Certified
Kansas *	E-10268	Tennessee	TN02839
Kentucky	90107	Texas *	T104704230-18-15
Louisiana *	LA180000	Utah (Primary AB) *	CA00006
Maine	CA0006	Vermont	VT0114
Maryland	224	Virginia *	460260
Commonwealth of Northern Marianas Is.	MP0004	Washington	C838
Massachusetts	M-CA006	EPA Region 5	Certified
Michigan	9906	Los Angeles County Sanitation Districts	10264
Mississippi	Certified		

* NELAP/TNI Recognized Accreditation Bodies

ISO/IEC 17025 Accredited Method List

The tests listed below are accredited and meet the requirements of ISO/IEC 17025 as verified by the ANSI-ASQ National Accreditation Board/ANAB. Refer to Certificate and scope of accreditation (AT 1807) found at: <https://www.eurofinsus.com/Eaton>

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Environmental (Drinking Water)	Environmental (Waste Water)	Water as a Component of Food and Bev/Bev/ Bottled Water
1,2,3-TCP (5 PPT & 0.5 PPT)	CA SRL 524M-TCP	x		x
1,4-Dioxane	EPA 522	x		x
2,3,7,8-TCDD	Modified EPA 1613B	x		x
Acrylamide	In House Method (2440)	x		x
Algal Toxins/Microcystin	In House Method (3570)			
Alkalinity	SM 2320B	x	x	x
Ammonia	EPA 350.1		x	x
Ammonia	SM 4500-NH3 H		x	x
Anions and DBPs by IC	EPA 300.0	x	x	x
Anions and DBPs by IC	EPA 300.1	x		x
Asbestos	EPA 100.2	x	x	
BOD / CBOD	SM 5210B		x	x
Bromate	In House Method (2447)	x		x
Carbamates	EPA 531.2	x		x
Carbonate as CO3	SM 2330B	x	x	x
Carbonyls	EPA 556	x		x
COD	EPA 410.4 / SM 5220D		x	
Chloramines	SM 4500-CL G	x	x	x
Chlorinated Acids	EPA 515.4	x		x
Chlorinated Acids	EPA 555	x		x
Chlorine Dioxide	SM 4500-CLO2 D Palin Test	x		x
Chlorine -Total/Free/ Combined Residual	SM 4500-CI G	x	x	x
Conductivity	EPA 120.1		x	
Conductivity	SM 2510B	x	x	x
Corrosivity (Langelier Index)	SM 2330B	x		x
Cyanide, Amenable	SM 4500-CN G	x	x	
Cyanide, Free	SM 4500CN F	x	x	x
Cyanide, Total	EPA 335.4	x	x	x
Cyanogen Chloride (screen)	In House Method (2470)	x		x
Diquat and Paraquat	EPA 549.2	x		x
DBP/HAA	SM 6251B	x		x
Dissolved Oxygen	SM 4500-O G		x	x
DOC	SM 5310C	x		x
E. Coli	(MTF/EC+MUG)	x		x
E. Coli	CFR 141.21(f)(6)(i)	x		x
E. Coli	SM 9223		x	
E. Coli (Enumeration)	SM 9221B.1/ SM 9221F	x		x
E. Coli (Enumeration)	SM 9223B	x		x
EDB/DCBP	EPA 504.1	x		
EDB/DCBP and DBP	EPA 551.1	x		x
EDTA and NTA	In House Method (2454)	x		x
Endothall	EPA 548.1	x		x
Endothall	In-house Method (2445)	x		x
Enterococci	SM 9230B	x	x	
Fecal Coliform	SM 9221 E (MTF/EC)	x		
Fecal Coliform	SM 9221C, E (MTF/EC)		x	
Fecal Coliform (Enumeration)	SM 9221E (MTF/EC)	x		x
Fecal Coliform with Chlorine Present	SM 9221E		x	
Fecal Streptococci	SM 9230B	x	x	
Fluoride	SM 4500-F C	x	x	x
Glyphosate	EPA 547	x		x
Glyphosate + AMPA	In House Method (3618)	x		x
Gross Alpha/Beta	EPA 900.0	x	x	x
Gross Alpha Coprecipitation	SM 7110 C	x	x	x
Hardness	SM 2340B	x	x	x
Heterotrophic Bacteria	In House Method (2439)	x		x
Heterotrophic Bacteria	SM 9215 B	x		x
Hexavalent Chromium	EPA 218.6	x	x	x

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Environmental (Drinking Water)	Environmental (Waste Water)	Water as a Component of Food and Bev/Bev/ Bottled Water
Hexavalent Chromium	EPA 218.7	x		x
Hexavalent Chromium	SM 3500-Cr B		x	
Hormones	EPA 539	x		x
Hydroxide as OH Calc.	SM 2330B	x		x
Kjeldahl Nitrogen	EPA 351.2		x	
Legionella	Legiolert	x		x
Mercury	EPA 245.1	x	x	x
Metals	EPA 200.7 / 200.8	x	x	x
Microcystin LR	ELISA (2360)	x		x
Microcystin, Total	EPA 546	x		x
NDMA	EPA 521 In house method (2425)	x		x
Nitrate/Nitrite Nitrogen	EPA 353.2	x	x	x
OCL, Pesticides/PCB	EPA 505	x		x
Ortho Phosphate	EPA 365.1	x	x	x
Ortho Phosphorous	SM 4500P E	x		x
Oxyhalides Disinfection Byproducts	EPA 317.0	x		x
Perchlorate	EPA 331.0	x		x
Perchlorate (low and high)	EPA 314.0	x		x
Perfluorinated Alkyl Acids	EPA 537	x		x
Perfluorinated Pollutant	In house Method (2434)	x		x
pH	EPA 150.1	x		
pH	SM 4500-H+B	x	x	x
Phenylurea Pesticides/ Herbicides	In House Method, based on EPA 532 (2448)	x		x
Pseudomonas	IDEXX Pseudalert (2461)	x		x
Radium-226	GA Institute of Tech	x		x
Radium-228	GA Institute of Tech	x		x
Radon-222	SM 7500RN	x		x
Residue, Filterable	SM 2540C	x	x	x
Residue, Non-filterable	SM 2540D		x	
Residue, Total	SM 2540B		x	x
Residue, Volatile	EPA 160.4		x	
Semi-VOC	EPA 525.2	x		x
Silica	SM 4500-Si D	x	x	
Silica	SM 4500-SiO2 C	x	x	
Sulfide	SM 4500-S ⁻ D		x	
Sulfite	SM 4500-SO ³ B	x	x	x
Surfactants	SM 5540C	x	x	x
Taste and Odor Analytes	SM 6040E	x		x
Total Coliform (P/A)	SM 9221 A, B	x		x
Total Coliform (Enumeration)	SM 9221 A, B, C	x		x
Total Coliform / E. coli	Colisure SM 9223	x		x
Total Coliform	SM 9221B		x	
Total Coliform with Chlorine Present	SM 9221B		x	
Total Coliform / E.coli (P/A and Enumeration)	SM 9223	x		x
TOC	SM 5310C	x	x	x
TOX	SM 5320B		x	
Total Phenols	EPA 420.1		x	
Total Phenols	EPA 420.4	x	x	x
Total Phosphorous	SM 4500 P E		x	
Triazine Pesticides & Degradates	In House (3617)	x		x
Turbidity	EPA 180.1	x	x	x
Turbidity	SM 2130B	x	x	
Uranium by ICP/MS	EPA 200.8	x		x
UV 254	SM 5910B	x		
VOC	EPA 524.2	x		x
VOC	In House Method (2411)	x		x
Yeast and Mold	SM 9610	x		x
Field Sampling	N/A			

Acknowledgement of Samples Received

Addr: **Rocky Harvest, LLC**
181 Rear Brook Street
Plympton, MA 02367

Client ID: CDI
Folder #: 851894
Project: 664-RKY
Sample Group: NY Annual

Attn: (664) Water Quality Manager - Plympton, MA
Phone:

Project Manager: Linda Geddes
Phone: (626) 386-1163

The following samples were received from you on **February 12, 2020** at **1458**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical, LLC.

Sample #	Sample ID	Sample Date																								
202001300028	664-033 Harvest Spring-Treated PWSID: 4240006	02/11/2020 0930																								
	<table border="1"> <tr> <td>@900</td> <td>@RA226 GA</td> <td>@RA228 GA</td> </tr> <tr> <td>@505</td> <td>@515.4</td> <td>@ANIONS28</td> </tr> <tr> <td>@ANIONS48</td> <td>@ICP</td> <td>@ICPMS</td> </tr> <tr> <td>@VOA</td> <td>Alkalinity in CaCO3 units</td> <td>Apparent Color</td> </tr> <tr> <td>Bicarb.Alkalinity as HCO3,calc</td> <td>Bromate by UV/VIS</td> <td>Fluoride</td> </tr> <tr> <td>Langelier Index - 25 degree</td> <td>Mercury ICPMS</td> <td>Odor at 60 C (TON)</td> </tr> <tr> <td>PH (H3=past HT not compliant)</td> <td>Total Dissolved Solid (TDS)</td> <td>Total Hardness as CaCO3 by ICP</td> </tr> <tr> <td>Turbidity</td> <td>Freight Return - NY Annual</td> <td></td> </tr> </table>	@900	@RA226 GA	@RA228 GA	@505	@515.4	@ANIONS28	@ANIONS48	@ICP	@ICPMS	@VOA	Alkalinity in CaCO3 units	Apparent Color	Bicarb.Alkalinity as HCO3,calc	Bromate by UV/VIS	Fluoride	Langelier Index - 25 degree	Mercury ICPMS	Odor at 60 C (TON)	PH (H3=past HT not compliant)	Total Dissolved Solid (TDS)	Total Hardness as CaCO3 by ICP	Turbidity	Freight Return - NY Annual		
@900	@RA226 GA	@RA228 GA																								
@505	@515.4	@ANIONS28																								
@ANIONS48	@ICP	@ICPMS																								
@VOA	Alkalinity in CaCO3 units	Apparent Color																								
Bicarb.Alkalinity as HCO3,calc	Bromate by UV/VIS	Fluoride																								
Langelier Index - 25 degree	Mercury ICPMS	Odor at 60 C (TON)																								
PH (H3=past HT not compliant)	Total Dissolved Solid (TDS)	Total Hardness as CaCO3 by ICP																								
Turbidity	Freight Return - NY Annual																									
202001300029	Trip Blanks- HOLD	02/11/2020 0930																								
	@VOASDWA TB																									

Test Description

- @900 -- Gross Alpha/Beta Radiation
- @RA226 GA -- Radium 226
- @RA228 GA -- Radium 228
- @505 -- Organochlorine Pesticides/PCBs
- @515.4 -- Chlorophenoxy Herbicides
- @ANIONS28 -- Chloride, Sulfate by EPA 300.0
- @ANIONS48 -- Nitrate, Nitrite by EPA 300.0
- @ICP -- ICP Metals
- @ICPMS -- ICPMS Metals
- @VOA -- Volatile Organics by GCMS
- @VOASDWA TB -- Volatile Organics by GCMS



Eaton Analytical

Kit Order for Compliance Designs

Linda Geddes is your Eurofins Eaton Analytical, LLC Service Manager

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
(626) 386-1100 FAX (866) 988-3757

Created Date & Time: 1/30/2020 8:33:27AM

Note: Sampler Please return this paper with your samples



Kit #: 255824



Client ID: CDI

Created By: Rachael Lucero - [BS2J]

Project Code: 664-RKY Bottle Orders

Deliver By: 02/05/2020

STG: Bottle Orders

Group Name: NY Annual

Ice Type: G

Pre Registered

PO#/JOB#:

Description: Harvest Spring-Treated

Ship Sample Kits to
 Harvest Spring
 743 Broad Street, Unit 1
 East Weymouth, MA 02189
 Attn: Ed Rose
 Phone: 781-749-4849

Send Report to
 Rocky Harvest, LLC
 181 Pear Brook Street
 Plymouth, MA 02367
UNITE!
E. WEYMOUTH, MA 02189
 Attn: (664) Water Quality Manager -
 Plympton, MA

Billing Address
 Compliance Designs, Inc.
 159 South Stark Highway
 Weare, NH 27539
 Attn: Nicki Ovens

# of Sample Tests	Bottle Qty - Type [preservative information]	Total	UN DOT #
1	@ANIONS28, @ANIONS48, Alkalinity in CaCO3 units, Fluoride, PH (H3=past HT not compliant)	1	
1	Apparent Color, Odor at 60 C (TON), Turbidity	1	
1	@RA226 GA	3	UN2031
1	@RA228 GA	3	UN2031
1	@ICP, Mercury ICPMS	1	UN2031
1	@505	4	
1	@VOA	4	UN1789
1	@VOASDWA TB	2	UN1789
1	@ICPMS	1	UN2031
1	@900	2	UN2031
1	Total Dissolved Solid (TDS)	1	
1	@515.4	4	
1	Bromate by UV/VIS	1	
Sum Tests: 13		Sum Bottles: 28	

Comments

SHIPPING: Send CDI COC. Sampling Instructions and Return Air Bill



Eaton Analytical

INTERNAL CHAIN OF CUSTODY RECORD

EEA Folder Number:

857694

SAMPLE TEMP RECEIVED:

Note: If samples are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.

SAMPLES REC'D DAY OF COLLECTION? Yes / No

IR Gun ID = 61168 (Observation = 5.3 °C) (Corr. Factor = -0.3 °C) (Final = 5.0 °C)

TYPE OF ICE: Real Synthetic No Ice CONDITION OF ICE: Frozen Partially Frozen Thawed N/A

METHOD OF SHIPMENT: Pick-Up / Walk-In (FedEx) / UPS / DHL / Area Fast / Top Line / Other: _____

Compliance Acceptance Criteria: 141005935839

- 1) Chemistry: >0, ≤ 6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥ 10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)

4) Dioxin (1613 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)

5) pH Check. Manufacturer: _____ Lot Number: _____ pH strip type: 0 - 14 or _____ Expiration Date _____ Results: _____

6) Chlorine check. Manufacturer: Sansafe. Lot No.: _____ Expiration Date _____ Results _____

7) VOA Headspace: No Samples with Headspace: Samples with Headspace (see below):
Headspace Documentation (use additional VOC Internal COFC for additional bottles)

Exempt from headspace concerns: Methods 515.4, HAA(6251,552), 505, SPME, @CH, 532LCMS, 556, 536, Anatoxin, LCMS methods using 40 ml vials, International clients:

Sample ID	Bottle #	None/<6	>6mm	Sample ID	Bottle #	None/<6	>6mm	Sample ID	Bottle #	None/<6	>6mm

Note Sample IDs which have dissimilar headspace (i.e. potential sampling errors): _____

RECEIVED BY:	SIGNATURE	PRINT NAME	COMPANY/TITLE	DATE	TIME
<u>Chuck Brooks</u>	<u>Chuck Brooks</u>	Chuck Brooks	Eurofins Eaton Analytical	<u>2-12-20</u>	<u>1458</u>

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report Date: 03/10/2020

Client: Rocky Harvest, LLC
181 Rear Brook Street
Plympton, MA 02367

Attention: (664) Water Quality Manager - Plympton, MA

Parameter	Method	Reporting Limit	Result
Sample ID: 664-033 Harvest Spring-Treated			Sample #: 202001300028
Primary Inorganics			
Antimony, Total, ICAP/MS	EPA 200.8	0.001	ND
Arsenic, Total, ICAP/MS	EPA 200.8	0.002	ND
Barium, Total, ICAP/MS	EPA 200.8	0.002	0.0068
Cadmium, Total, ICAP/MS	EPA 200.8	0.0005	ND
Chromium, Total, ICAP/MS	EPA 200.8	0.005	ND
Fluoride	SM 4500F-C	0.05	ND
Lead, Total, ICAP/MS	EPA 200.8	0.0005	ND
Mercury	EPA 200.8	0.0002	ND
Nickel, Total, ICAP/MS	EPA 200.8	0.005	ND
Nitrate as Nitrogen by IC	EPA 300.0	0.1	0.71
Nitrite, Nitrogen by IC	EPA 300.0	0.05	ND
Total Nitrate and Nitrite	EPA 300.0	0.1	0.71
Selenium, Total, ICAP/MS	EPA 200.8	0.005	ND
Secondary Inorganics			
Alkalinity in CaCO3 units	SM 2320B	2	17
Bicarb.Alkalinity as HCO3,calc	SM2330B	2	21
Calcium, Total, ICAP	EPA 200.7	1	6.6
Chloride	EPA 300.0	0.5	12
Copper, Total, ICAP/MS	EPA 200.8	0.002	ND
Corrosivity, Units	SM 2330B	-14	-2.6
Hardness, Total	SM 2340B	3	27
Iron, Total, ICAP	EPA 200.7	0.02	ND
Magnesium, Total, ICAP	EPA 200.7	0.1	2.5
Manganese, Total, ICAP/MS	EPA 200.8	0.002	0.0037
pH (units)	SM4500-HB	0.1	6.7
Silver, Total, ICAP/MS	EPA 200.8	0.0005	ND
Sodium, Total, ICAP	EPA 200.7	1	7.9
Sulfate	EPA 300.0	0.5	7.7
Total Dissolved Solids (TDS)	E160.1/SM2540C	10	64
Zinc, Total, ICAP/MS	EPA 200.8	0.02	ND

Physical

All results reported in milligrams per liter unless otherwise noted.
ND - Not detected at the specified limit

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report Date: 03/10/2020

Client: Rocky Harvest, LLC
181 Rear Brook Street
Plympton, MA 02367

Attention: (664) Water Quality Manager - Plympton, MA

Parameter	Method	Reporting Limit	Result
Sample ID: 664-033 Harvest Spring-Treated			Sample #: 202001300028
Color (ACU)	SM 2120B	3	ND
Odor at 60C (TON)	SM 2150B	1	1.0
Turbidity (NTU)	EPA 180.1	0.1	0.13
Volatile Organic Compounds			
Benzene	EPA 524.2	0.0005	ND
Bromobenzene	EPA 524.2	0.0005	ND
Bromochloromethane	EPA 524.2	0.0005	ND
Bromodichloromethane	EPA 524.2	0.0005	ND
Bromoform	EPA 524.2	0.0005	ND
Bromomethane	EPA 524.2	0.0005	ND
n-Butylbenzene	EPA 524.2	0.0005	ND
sec-Butylbenzene	EPA 524.2	0.0005	ND
tert-Butylbenzene	EPA 524.2	0.0005	ND
Carbon Tetrachloride	EPA 524.2	0.0005	ND
Chlorobenzene	EPA 524.2	0.0005	ND
Chloroethane	EPA 524.2	0.0005	ND
Chloroform (Trichloromethane)	EPA 524.2	0.0005	ND
Chloromethane(Methyl Chloride)	EPA 524.2	0.0005	ND
2-Chlorotoluene	EPA 524.2	0.0005	ND
4-Chlorotoluene	EPA 524.2	0.0005	ND
Chlorodibromomethane	EPA 524.2	0.0005	ND
Dibromomethane	EPA 524.2	0.0005	ND
1,2-Dichlorobenzene (1,2-DCB)	EPA 524.2	0.0005	ND
1,3-Dichlorobenzene	EPA 524.2	0.0005	ND
1,4-Dichlorobenzene	EPA 524.2	0.0005	ND
Dichlorodifluoromethane	EPA 524.2	0.0005	ND
1,1-Dichloroethane	EPA 524.2	0.0005	ND
1,2-Dichloroethane	EPA 524.2	0.0005	ND
1,1-Dichloroethylene	EPA 524.2	0.0005	ND
cis-1,2-Dichloroethylene	EPA 524.2	0.0005	ND
trans-1,2-Dichloroethylene	EPA 524.2	0.0005	ND
1,2-Dichloropropane	EPA 524.2	0.0005	ND
1,3-Dichloropropane	EPA 524.2	0.0005	ND
2,2-Dichloropropane	EPA 524.2	0.0005	ND

All results reported in milligrams per liter unless otherwise noted.
ND - Not detected at the specified limit

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report Date: 03/10/2020

Client: Rocky Harvest, LLC
181 Rear Brook Street
Plympton, MA 02367

Attention: (664) Water Quality Manager - Plympton, MA

Parameter	Method	Reporting Limit	Result
Sample ID: 664-033 Harvest Spring-Treated			Sample #: 202001300028
1,1-Dichloropropene	EPA 524.2	0.0005	ND
cis-1,3-Dichloropropene	EPA 524.2	0.0005	ND
trans-1,3-Dichloropropene	EPA 524.2	0.0005	ND
Di-Isopropyl ether	EPA 524.2	0.003	ND
Ethyl benzene	EPA 524.2	0.0005	ND
Hexachlorobutadiene	EPA 524.2	0.0005	ND
Isopropylbenzene	EPA 524.2	0.0005	ND
4-Isopropyltoluene	EPA 524.2	0.0005	ND
4-Methyl-2-Pentanone (MIBK)	EPA 524.2	0.005	ND
Methyl Tert-butyl ether (MTBE)	EPA 524.2	0.0005	ND
Methyl Ethyl Ketone (MEK)	EPA 524.2	0.005	ND
Methylene Chloride (Dichloromethane)	EPA 524.2	0.0005	ND
Naphthalene	EPA 524.2	0.0005	ND
n-Propylbenzene	EPA 524.2	0.0005	ND
Styrene	EPA 524.2	0.0005	ND
Tert-Amyl Methyl Ether (TAME)	EPA 524.2	0.003	ND
Tert-Butyl Ethyl Ether (TBEE)	EPA 524.2	0.003	ND
1,1,1,2-Tetrachloroethane	EPA 524.2	0.0005	ND
1,1,2,2-Tetrachloroethane	EPA 524.2	0.0005	ND
Tetrachloroethylene (PCE)	EPA 524.2	0.0005	ND
Toluene	EPA 524.2	0.0005	ND
1,2,3-Trichlorobenzene	EPA 524.2	0.0005	ND
1,2,4-Trichlorobenzene	EPA 524.2	0.0005	ND
1,1,1-Trichloroethane	EPA 524.2	0.0005	ND
1,1,2-Trichloroethane	EPA 524.2	0.0005	ND
Trichloroethylene (TCE)	EPA 524.2	0.0005	ND
Trichlorofluoromethane (Freon 11)	EPA 524.2	0.0005	ND
Trichlorotrifluoroethane(Freon 113)	EPA 524.2	0.0005	ND
1,2,3-Trichloropropane	EPA 524.2	0.0005	ND
1,2,4-Trimethylbenzene	EPA 524.2	0.0005	ND
1,3,5-Trimethylbenzene	EPA 524.2	0.0005	ND
Vinyl chloride (VC)	EPA 524.2	0.0003	ND
Total xylenes	EPA 524.2	0.0005	ND
m,p-Xylenes	EPA 524.2	0.0005	ND
o-Xylene	EPA 524.2	0.0005	ND

All results reported in milligrams per liter unless otherwise noted.
ND - Not detected at the specified limit

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report Date: 03/10/2020

Client: Rocky Harvest, LLC
181 Rear Brook Street
Plympton, MA 02367

Attention: (664) Water Quality Manager - Plympton, MA

Parameter	Method	Reporting Limit	Result
Sample ID: 664-033 Harvest Spring-Treated			Sample #: 202001300028
Carbon Disulfide	EPA 524.2	0.0005	ND
Pesticides and PCBs			
Alachlor (Alanex)	EPA 505	0.0001	ND
Aldrin	EPA 505	0.00001	ND
Chlordane	EPA 505	0.0001	ND
Dieldrin	EPA 505	0.00001	ND
Endrin	EPA 505	0.00001	ND
Heptachlor	EPA 505	0.00001	ND
Heptachlor Epoxide	EPA 505	0.00001	ND
Lindane (gamma-BHC)	EPA 505	0.00001	ND
Methoxychlor	EPA 505	0.00005	ND
Total PCBs	EPA 505	0.0001	ND
PCB 1016 Aroclor	EPA 505	0.00008	ND
PCB 1221 Aroclor	EPA 505	0.0001	ND
PCB 1232 Aroclor	EPA 505	0.0001	ND
PCB 1242 Aroclor	EPA 505	0.0001	ND
PCB 1248 Aroclor	EPA 505	0.0001	ND
PCB 1254 Aroclor	EPA 505	0.0001	ND
PCB 1260 Aroclor	EPA 505	0.0001	ND
Toxaphene	EPA 505	0.0005	ND
Herbicides			
2,4,5-T	EPA 515.4	0.0002	ND
2,4,5-TP (Silvex)	EPA 515.4	0.0002	ND
2,4-D	EPA 515.4	0.0001	ND
2,4-DB	EPA 515.4	0.002	ND
Dichlorprop	EPA 515.4	0.0005	ND
Acifluorfen	EPA 515.4	0.0002	ND
Bentazon	EPA 515.4	0.0005	ND
Dalapon	EPA 515.4	0.001	ND
3,5-Dichlorobenzoic acid	EPA 515.4	0.0005	ND
Tot DCPA Mono&Diacid Degradate	EPA 515.4	0.0001	ND
Dicamba	EPA 515.4	0.0001	ND
Dinoseb	EPA 515.4	0.0002	ND

All results reported in milligrams per liter unless otherwise noted.
ND - Not detected at the specified limit

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report Date: 03/10/2020

Client: Rocky Harvest, LLC
181 Rear Brook Street
Plympton, MA 02367

Attention: (664) Water Quality Manager - Plympton, MA

Parameter	Method	Reporting Limit	Result
Sample ID: 664-033 Harvest Spring-Treated			Sample #: 202001300028
Pentachlorophenol	EPA 515.4	0.00004	ND
Picloram	EPA 515.4	0.0001	ND
Disinfection By-products			
Bromate	EPA 317	0.005	ND
Total Trihalomethanes	EPA 524.2	0.0005	ND
Other Compounds			
Alpha, Gross, pCi/L	EPA 900.0	3	ND
Beta, Gross, pCi/L	EPA 900.0	3	ND
Radium 226, pCi/L	Ra-226 GA	1	ND
Radium 228, pCi/L	RA-228 GA	1	ND